

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1170437

**Product:** Switchgear assembly

**Type:** MR see annex

**Rating:** 3+N+PE, 400/230 V AC, 50 Hz, TN-C-S, to 63 A, to 10 kA, IP54

**Ordering firm:** INGOS s.r.o.  
K Nouzovu 2090, 143 00 Praha 4, Czech Republic

**Manufacturer:** INGOS s.r.o.  
K Nouzovu 2090, 143 00 Praha 12, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 701554-01/01 of: 25.05.2017

**A sample of the product was found to be in conformity with:**  
ČSN EN 61439-2 ed. 2:12, ČSN EN 61439-1 ed. 2:12

**Other data:**

Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 701554 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 117/2016 Sb., 118/2016 Sb. as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

**The validity of the certificate is limited to:** 30.06.2020

23.06.2017 corrigendum 26.06.2017

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



701554-01